certifire

CERTIFICATE OF APPROVAL No CF 625

This is to certify that, in accordance with TS00 General Requirements for Certification of Fire Protection Products The undermentioned products of

PREMDOR CROSBY LIMITED

Birthwaite Business Park, Huddersfield Road, Darton, Barnsley, S75 5JS Tel: 0844 371 5350

Have been assessed against the requirements of the Technical Schedule(s) denoted below and are approved for use subject to the conditions appended hereto:

CERTIFIED PRODUCT Premdor Crosby Limited FD30 PremCORE Lite (L) TECHNICAL SCHEDULE TS10 Fire Resisting Door Assemblies with Non Metallic Leaves

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan Certification Manager



Issued: Re-issued: Valid to: 1st September 2008 8th May 2024 25th November 2028

Page 1 of 3



This certificate is the property of Warringtonfire Testing and Certification Limited Registered in England and Wales Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

certifire **CERTIFICATE No CF 625** PREMDOR CROSBY LIMITED

PREMDOR CROSBY LIMITED - FD30 PremCORE Lite (L)

This approval relates to the use of the above door assemblies in providing fire resistance of 30 minutes integrity and 30 minutes insulation (if incorporating not more than 20% of uninsulating glass) as defined in BS 476: Part 22: 1987. Subject to the undermentioned conditions, the doors will meet the relevant requirements of BS 5588 for FD30 door assemblies when used in accordance with the provisions therein.

- 1. This certification is provided to the client for its own purposes, and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- 2. The doors are approved on the basis of:
 - i) Initial type testing
 - ii) A design appraisal against TS10
 - Inspection and surveillance of factory production control iii)
 - iv) Certification under a CERTIFIRE approved Quality Management System
 - v) Audit testing at the frequency specified in TS10
- 3. The doors comprise door leaves with a chipboard core, for use with timber frames, with intumescent edge seals (code ITT FD30).
- 4. This approval is applicable to both complete door assemblies and door leaves. Where the door is not supplied in a fully fitted form it is a condition of this approval that an agreed Data Sheet accompanies the product and is complied with in its entirety. Failure to do so will invalidate this approval and may jeopardise the fire performance of the door.
- This approval is applicable to single and double-acting, single and double-leaf, latched and 5. unlatched ITT assemblies at leaf dimensions up to those given in Table 1 below.

Door assembly configuration	Maximum Height	Maximum Width	Area
	(mm)	(mm)	(m²)
Single-Acting, Single-Leaf	2126	1010	2.0
Latched / Unlatched	(at 981 wide)	(at 1981 high)	
Single-Acting, Double-Leaf	2126	1010	2.0
Latched / Unlatched	(at 981 wide)	(at 1981 high)	
Double-acting, Single-leaf	2126 (at 981 wide)	1010 (at 1981 high)	2.0
Double-acting, Double-leaf	2126 (at 981 wide)	1010 (at 1981 high)	2.0
Table 1.			

Note: Under no circumstances must either the maximum height or maximum width be exceeded without separate CERTIFIRE approval.

Both leaves of double-leaf assemblies are to be of identical construction.

Secondary leaves for unequal pairs shall be a min 30% of the primary leaf width.

Signed CQT44599-1 CQT44599-3

ful ligg-

1st September 2008 Issued: Re-issued: 8th May 2024 Valid to: 25th November 2028

Page 2 of 3

Registered Office: 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA. Company Registration No: 11371436

CERTIFICATE No CF 625 PREMDOR CROSBY LIMITED

PREMDOR CROSBY LIMITED - FD30 PremCORE Lite (L)

- 6. Glazing shall only be undertaken by the door manufacturer, or a CERTIFIRE approved Licensed Door Processor, and shall be in accordance with the Data Information Sheet and Construction Specification. No site cutting or glazing of apertures is permitted.
- 7. Hardware items, including closing devices and intumescent edge seals, shall be as specified in the Data Sheet.
- 8. The door assemblies shall be mechanically fixed to wall constructions having a fire resistance of at least 30 minutes.
- Labels to the CERTIFIRE design, or approved by CERTIFIRE, CERTIFIRE and CERTIFIRE Ref. No. CF625 and FD30 classifications resistance shall be affixed to each door in the prescribed position.
- 10. This approval relates to on-going production. The product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name and mark together with the CERTIFIRE Certificate number and application where appropriate.

Signed CQT44599-1 CQT44599-3

Pul ligg-

Issued: Re-issued: Valid to:

1st September 2008 : 8th May 2024 25th November 2028

Page 3 of 3